

LPI INTERNAL INSPECTION PROCEDURE

TOWN _____ PERMIT # _____ MAP# _____ LOT# _____

INSTALLED BY: HOMEOWNER; -----MASTER PLUMBER # _____ OTHER _____

FIRST INSPECTION DATE: ____/____/____

- | <u>YES</u> | <u>NO</u> | |
|------------|-----------|---|
| 1) _____ | _____ | Test gauges used are of correct psi rating |
| 2) _____ | _____ | Drainage air test is 5psi for 15 min. or complete system has a 10' head of water. |
| 2) _____ | _____ | Water pipe air test is 50 psi for 15 min. or at working pressure. |
| 3) _____ | _____ | Pipes are charged with air |
| 3) _____ | _____ | Horizontal drain lines more than 5' have a cleanout at it's upper terminal and other proper locations. |
| 4) _____ | _____ | Cleanouts 2" or less in size have a clearance or 12" and larger than 2" have a clearance of 18". |
| 5) _____ | _____ | Horizontal drainage piping has pitch of not less then 1/4 per foot. |
| 6) _____ | _____ | Drainage fittings are used correctly |
| 7) _____ | _____ | Support for copper piping is at 6' intervals. |
| 8) _____ | _____ | Support for drainage piping is at 4' intervals. |
| 9) _____ | _____ | Sewer ejector pump station has a check and gate valve on the discharge pipe and is vented properly. |
| 10) _____ | _____ | All vents extending through the roof are not less than 24". |
| 11) _____ | _____ | All vents which are extending through the roof are 10' away and/or 3' above any window or air intake opening. |
| 12) _____ | _____ | Dishwashers are connected with an air gap. |
| 13) _____ | _____ | Laundry units in basement connected to a pump to eject gray water to proper waste line. |
| 14) _____ | _____ | Water arrestors are installed on all quick-acting valves. |
| 14) _____ | _____ | All commercial plumbing applications dealing with either food or drink are hooked up with an indirect waste. |
| 15) _____ | _____ | All fixtures are properly vented and trapped in accordance to the plumbing rules. |
| 17) _____ | _____ | Water heating units are properly installed with the correct temperature and pressure relief valve, vacume breaker & unions. |

SECOND INSPECTION DATE: ____/____/____

- | | | |
|----------|-------|--|
| 1) _____ | _____ | All fixtures are working properly and free from leaks. |
| 2) _____ | _____ | Ejector pumps, garbage disposals are working properly. |
| 3) _____ | _____ | Outside faucets have vacume breakers. |
| 4) _____ | _____ | The permit is signed off. |

APPROVED BY LPI

DATE

DEPARTMENT OF HUMAN SERVICES
DIVISION OF HEALTH ENGINEERING
ATTATCH TO TOWN COPY OF PERMIT